

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. TC9964240000000763F

Dated: 02.07.2024

It is certified that an inspection team headed by **NAVEEN KUMAR SURI (SAMPLING ASSIS.)** (Name of Officers with designation) from **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY** inspected the **JINGLE BELLS PUBLIC SCHOOL, CHHOTI BIHAR, PIIBHIT BY PASS ROAD, BAREILLY , UTTAR PRADESH** on **01/07/2024** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **LAB/BLY/2024-25/763** dated **02.07.2024** Of **UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab)** certified that the **JINGLE BELLS PUBLIC SCHOOL, CHHOTI BIHAR, PIIBHIT BY PASS ROAD, BAREILLY , UTTAR PRADESH** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 02-07-024 to 01-07-025

Signature with Seal:
Name :
Designation :
Name & Address of the Official Department :


Vipin Kumar Singh
Assistant Engineer
J.P. Jal Nigam, Bareilly (R)



To

MANAGER
JINGLE BELLS PUBLIC SCHOOL,
CHHOTI BIHAR, PIIBHIT BY PASS
ROAD, BAREILLY , UTTAR
PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


प्रबन्धक

जिंगल बेल्लस पब्लिक स्कूल शिक्षा समिति
छोटी बिहार, निकट महानगर,
पीलीभीत बाईपास रोड, बरेली

	Analysis Report	
	District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL)	
	Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)	

Customer Details	
Office Name and Address	JINGLE BELLS PUBLIC SCHOOL, CHHOTI VIHAR, PILIBHIT BY PASS ROAD, BAREILLY

Ref Letter No & Date	0	DATE - 01.07.2024	Report No.- LAB/BLY/2024-25/763
----------------------	---	-------------------	---------------------------------

Basic details of sample					
District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	01.07.2024
Village	CHHOTI VIHAR	Block	.	Analysis Completion Date	02.07.2024
Habitation	NEAR FUN CITY	Location	IN SCHOOL	Report Issue Date	02.07.2024
Water Source	SUBMERSIBLE	Sample Code	PS-763	Sample Depositor	VIJAY PAL
Quantity of Sample	1 ltr	Date of Sample Collection	01.07.2024		
Receiving Date	01.07.2024	Sample Collector	VIJAY PAL		

Environmental Condition			
Temperature	27°C	Humidity	57%


Technical Data of Analysis						
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(Hazen)	0	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
4	Turbidity	(NTU)	0.67	1.00	5.00	IS 3025 (Part 10) : 2022
5	TDS	(mg/L)	215	500	2000	IS 3025 (Part 16) : 2022
6	PH	-	7.89	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
7	Iron	(mg/L)	0.3	1.00	1.00	IS:3025(Part-53):2014
8	Sulphate	(mg/L)	15.1	200	400	IS 3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	178	200	600	IS 3025 (Part 23) : 2019
10	Hardness	(mg/L)	166	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	8	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	56	75	200	IS:3025(Part-40):2019
13	Magnesium	(mg/L)	26.7	30	100	APHA 23 Edition 3500Mg Method B

Note	1. This Certificate refers only to the particular sample(s) submitted for testing.
	2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
	3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
	4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Page no.: 1/1

Email - anamika05anu@gmail.com
U.P.J.N. BAREILLY (RURAL) Cont.No:- 7318253236


Prepared By
(Anil Kumar)


Approved By
(Anamika Singh)

अनिल कुमार
गुणवत्ता प्रबन्धक
जल विश्लेषण प्रयोगशाला
उ० प्र० जल निगम बरेली (ग्रामीण)

END OF THE REPORT

प्रबन्धक

जिंगल बेल्लस पब्लिक स्कूल शिक्षा समिति
छोटी बिहार, निकट महानगर,
पीलीभीत बाईपास रोड, बरेली

अनामिका सिंह
तकनीकि प्रबन्धक
जल विश्लेषण प्रयोगशाला
उ० प्र० जल निगम, बरेली (ग्रामीण)